
Declaration of Conformity

We, the undersigned

Company	CONTRIVE S.r.l.	
Address, City	Via Enrico Fermi 18 24040 Suisio (Bergamo)	
Country	Italy	
Phone number	+39 35 4948236	
E-mail address	info@contrive.it	



CERTIFY AND DECLARE UNDER OUR SOLE RESPONSIBILITY THAT THE FOLLOWING EQUIPMENT

Product description	BURNER CONTROL UNIT
Туре	QBK
P.I.N.	0063CS1560
Manufacturer	CONTRIVE S.r.l.
Technology	Complex electronic
Electrical supply	115/230 Vac 50/60 Hz
Gas valve output	250Vac / max 2A / cosφ =0.7
IP protection degree	IP64
Ambient temperature	-20 to +60 °C
Fuel type	Gas and/or Oil
Flame detection	Ionization or UV
Burner control Class	С
Reset function Class	В
Pollution degree	1 or 2 (EN60730-1:2011)
Available Versions	QBK FULL
	QBK BASIC
	QBK MINI



is tested to and conforms with the relevant **Union harmonization legislation**:

- Gas Appliances Directive (EU) 2009/142 GAD until April 21st 2018
- Gas Appliances Regulation (EU) 2016/426 GAR from April 21st 2018
- Low Voltage Directive (EU) 2014/35 LVD
- Electromagnetic Compatibility Directive (EU) 2014/30
- Restriction of Hazardous Substances Directive (EC) 2012/18 RoHS
- Registration, Evaluation, Authorization and Restriction of Chemicals (EC) Directive 1907/2006 REACH

The following harmonized standards and technical specification have been applied:

- EN298:2012
- EN14459:2007, Annex J

Basic risk evaluated	Safety functions
Explosion	Controlling ON-OFF gas valves
Fire	Safety timing and non-volatile lockout
	Flame supervision
	Local and remote reset function
Poisoning (combustion gases)	Air supervision (FULL version only)
Hot surfaces	Not applicable
Exposure to harmful substances	Not applicable

NOTIFIED BODY: 0063 - KIWA Nederland B.V. - Certificate number: 18GR0738/00

Suisio, April 20th 2018

CONTRIVE S.r.l.

Via Enrico Fermi 18 I-24040 Suisio (Bergamo) Giovanni Pedruzzi President